

Page
Seite 1 / 2

Customer:

Kunde:

Wika Alexander Wiegand SE & co KG
Alexander Wiegand Strasse, 30
63911 KLINGENBERGDE

Certificate No.
Zeugnis-Nr.**CRT29531**Date
Datum**07/11/2024**Customer Order No.
Kundenbestellnummer**P04717956**Customer Part. No.
Kunden Artikel-Nr.**5350.30**Order Date
Bestelldatum**07/10/2024**Order No. / Item
Auftrags-Nr. / Pos.**SO00014473/1**Part No.
Artikel-Nr.**81510733**Quantity
Menge**2,00**Model
TypSerial number
Seriennummer**[1*]**Scale range
AnzeigebereichClass
KlasseTag No.
Messstellen-Nr.**[2*]**Article text
Artikeltext

TW15-H 1/2 BSPT M20x1,5 female U=200 mm B=0.260 inch (6.6 mm) SS316/316L
Process thread [P or E]: 1/2 BSPT
Connection to thermometer [N]: M20x1,5 female
Thermowell style: Tapered
Head length [H]: 50 mm
Insertion length [U]: 200 mm
Root diameter [Q]: 16 mm
Tip diameter [V or F3]: 13 mm
Bore size [B or d1]: 0.260 inch (6.6 mm)
Bore depth / stem length (US) [A]: 243 mm
Specifications according to data sheet: TW 95.15

Test certificate acc. to EN 10204 2.2
Certificate Language: English and German
Thermowell / protection tube
Formal certificate: Manufactured according to state-of-the-art
Inspection certificate acc. to DIN EN 10204 3.1
Certificate Language: English and German
Thermowell / protection tube
Material certificate: Wetted parts material (metal contents) with mill certificate incl. chemical analysis
Pressure and stability test: Hydrostatic, internal pressure test - 500 bar (7500 psig) - 3 min.
Unit of measure: Metric (mm) Insertion length [U]: 200 mm

We herewith certify that above mentioned unit(s) complied with state-of-the-art technology at the time of supply. The order specifications were adhered to. The quality of the unit(s) was confirmed by the Quality Management System. The quality inspection has been successfully passed.

Hiermit bescheinigen wir, dass vorgenannte Einheit(en) zum Zeitpunkt des Inverkehrbringens, dem Stand der Technik entsprochen haben. Die Bestellvorgaben wurden eingehalten. Die Qualität der Einheit(en) wurde im Rahmen des Qualitätsmanagement-Systems sichergestellt. Die Qualitätsprüfung



Page
Seite 2 / 2

Customer:

Kunde:

**Wika Alexander Wiegand SE & co KG
Alexander Wiegand Strasse, 30
63911 KLINGENBERGDE**

Certificate No.

Zeugnis-Nr.

CRT29531

Date

Datum

07/11/2024

ergab keine Beanstandung.

[1*]

90700U2G # 90700U2H

[2*]

TIT-RU0001A-03 # TIT-RU0001B-03

Inspection Representative

Abnahmebeauftragter

Pierluigi Guindani

The inspection certificate was created electronically and is hereby validated by named inspection representative. This document is valid without signature.

Dieses Abnahmeprüfzeugnis wurde elektronisch erstellt und wird hiermit vom genannten Abnahmebeauftragten bestätigt. Das Dokument gilt ohne Unterschrift.