



BINA EPC Contractor Co.
(Executor of Oil, Gas, Petrochemical & Power Industries)

Toase-ehe Park Sanati Gohar Ofogh Petrochemical Co.

**CONCEPTUAL, BASIC and DETAIL DESIGN
ENGINEERING OF STYRENE PARK OFFSITE**

Document Title: Equipment Data Sheet-Active Carbon Filter

Document No. : EI0127-HRC-VD-ME-DSH-001-R0

ENBR
TEKNOLOJI



Rev.: R0

Page 1 of 4

STYRENE PARK OFFSITE

Document Title:

Equipment Data Sheet-Active Carbon Filter

Based on K.O.M, related duty spec. shall be filled out next to this data sheet.

Rev.	Issued Date	DESCRIPTION	PREPARED	CHECKED	APPROVED
R0	20/02/2024	Issued for Comment	M.Tavakoli	E.Malek	H.Keshmiri



Toase-eh Park Sanati Gohar Ofogh Petrochemical Co.
**CONCEPTUAL, BASIC and DETAIL DESIGN ENGINEERING OF
 STYRENE PARK OFFSITE**



Document Title: Equipment Data Sheet-Active Carbon Filter

Document No. : EI0127-HRC-VD-ME-DSH-001-R0

Rev.: R0 Page 2 of 4

Page	Revisions						
	R0	R1	R2	R3	R4	R5	R6
1	X						
2	X						
3	X						
4	X						
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							

Page	Revisions						
	R0	R1	R2	R3	R4	R5	R6
41							
42							
43							
44							
45							
46							
47							
48							
49							
50							
51							
52							
53							
54							
55							
56							
57							
58							
59							
60							
61							
62							
63							
64							
65							
66							
67							
68							
69							
70							
71							
72							
73							
74							
75							
76							
77							
78							
79							
80							



BINA EPC Contractor Co.
(Executor of Oil, Gas, Petrochemical & Power Industries)

Toase-eh Park Sanati Gohar Ofogh Petrochemical Co.

CONCEPTUAL, BASIC and DETAIL DESIGN ENGINEERING OF STYRENE
PARK OFFSITE

ENBR
TEKNOLOJI



Document Title: Equipment Data Sheet-Active Carbon Filter

Document No. : EI0127-HRC-VD-ME-DSH-001-R0

Rev.: R0

Page 3 of 4

General

1	Items	QTY	Active Carbon Filter	2
2	Tags	Shall be acc. to project docs. PK0001-F1 , PK0002-F1		
3	Service	VOC abatement from styrene storage tank effluent		

Process Data

Item	Description	Unit	Value	Rev.
4	Max. Ambient Design Temperature.	°C	85	
5	Expected Extreme Temperature	°C	52	
6	Min. Ambient Temperature	°C	5	
7	Max. Relative Humidity	%	80	
8	Min. Relative Humidity	%	65	

Process Data

Item	Description	Unit	Value	Rev.
9	Type of Fluid		Air+Styrene (3.5 g/Nm3)	
10	Flow Rate (Nor/Max)	Nm3/hr	1080 / 1188 (Note 1)	
11	Working Temperature (Min/Max)	°C	5 / 52	
12	Working Pressure	barg	max 0.07	
13	Design Temperature	°C	85	
14	Design Pressure	barg	-0.1 ~ 0.2	
15	Viscosity (Min./Max)	cP	0.018 / 0.020	
16	Density (Min./Max)	Kg/m3	1.107 / 1.295	
17	Styrene Inlet concentration		3.5 g/Nm3	
18	Styrene Outlet concentration		< 50 mg/Nm3	
19	Dirty / Clean pressure drop	bar	0.03 / 0.02	
19	Insulation		No	

Mechanical Data

Item	Description	Unit	Value	Rev.
20	Shell Inside Diameter	mm	2100	
21	Shell Length (T.L. / T.L.)	mm	5300	
22	Thickness (SHELL / HEAD)	mm	8 / 4.8 Min. A.F.	
23	Corrosion allowance	mm	3.0	
24	Radiography (SHELL / HEAD)	%	85 / 85	
25	MDMT (Required)	°C	-5	
26	Hydrostatic Test Pressure	barg	Hold	
27	PWHT	-	No	
28	Impact test	-	No	
31	Activated Carbon Bed Height	m	4.5	
32	Painting		Acco. To Painting Spec.	
33	Empty Weight	Kg	~ 4800	
34	Operating Weight	Kg	~ 12350	



BINA EPC Contractor Co.
(Executor of Oil, Gas, Petrochemical & Power Industries)

Toase-eh Park Sanati Gohar Ofogh Petrochemical Co.

CONCEPTUAL, BASIC and DETAIL DESIGN ENGINEERING OF STYRENE
PARK OFFSITE



Document Title: Equipment Data Sheet-Active Carbon Filter

Document No. : EI0127-HRC-VD-ME-DSH-001-R0

Rev.: R0

Page 4 of 4

Material guarantee regarding site conditions is in vendor scope. (considering suitable painting & coating)

Material

Item	Description	Value	Rev.
1	Shell & Head	SA 516 Gr.70	
2	Fittings	SA 234 GR.WPB	
3	Reinforcing Pad	SA 516 Gr.70	
4	Leg	SA 36	
5	Nozzle Neck Shall be recheck with geneal arrangement document	SA 106 Gr. B	
6	Forgings (including Flanges, etc)	SA 105	
7	Gasket	Spiral Wound (S.S.304/ Graphite)	
8	Media	Activated Carbon	
9	Removable / Welded Internals	SS304 / CS	
10	Stud Bolt & Nut (External)	SA 193 Gr.B7 & SA 194 Gr.2H	
11	Stud Bolt & Nut (Internal)	SA 193 Gr.B8 & SA 194 Gr.8	

Media

Item	Description	Value	Rev.
12	Type	Bed	
13	Material	Activated Carbon (Note 2)	
14	Shape Type / Dimension	Extrude / 5 mm dia.	
15	Media bulk density	450 kg/m3	
16	Bed Volume	15.6 m3	
17	Media Replacing Time	One year	

Nozzels

Item	Description	QTY	Size	Type	Rating	Face	SCH	Rev.
18	Vent	1	2"	S.O.	150	R.F.	Hold	
19	Drain	1	3"	S.O.	150	R.F.	Hold	
20	Gas inlet	1	6"	S.O.	150	R.F.	Hold	
21	Gas outlet	1	6"	S.O.	150	R.F.	Hold	
22	Utility Connection	1	2"	S.O.	150	R.F.	Hold	
23	MW	2	24"	S.O.	150	R.F.	Hold	

Accessories

Item	Description	Rev.
24	<input checked="" type="checkbox"/> Nameplate	
25	<input checked="" type="checkbox"/> Lifting Lug	
26	<input checked="" type="checkbox"/> Earth Lug	
27	<input checked="" type="checkbox"/> Ladder and Platform	
28	<input checked="" type="checkbox"/> Internals (Inlet distributor, bed supports)	
29	<input checked="" type="checkbox"/> Davit for manhole	

Notes

- 1- Feed stream is intermittent at loading time of upstream styrene storage tank.
- 2- Non-regenerable Carbon Active.