



	Gachsaran Polymer Industries Company HDPE Plant	
	Instrument Cable List for Refrigerator Package	 
PO No.: GPIC-PT-MA-PO-000-3029	Document Number: VD-GPIC-MA-3029-3029-0052	Rev. 02 Page 1 of 8

Instrument Cable List for Refrigerator Package




Code1	<input type="checkbox"/> No Comment/ Approved (Applicable Only for "FOR REVIEW" and "For Approval" Documents) No comment and the document are released for Manufacturing.
Code2	<input type="checkbox"/> No Comment/ Approved with Note(s) Vendor/Sub-Contractor shall correct, revise and resubmit the document. The document is released for Manufacturing if changes incorporated.
Code3	<input checked="" type="checkbox"/> Commented Vendor/Sub-Contractor shall correct, revise and resubmit the document by the date specified. The document shall be revised under the Status of "R: Revised Issue". All corrected documents shall be resubmitted before starting the Manufacturing Process.
Code 4	<input type="checkbox"/> Not Accepted (Rejected) Vendor/Sub-Contractor shall re-work / re-design / re-specify the contents of the document according to the comments / reasons for rejection. All corrected documents shall be resubmitted before starting the manufacturing. Vendor/Sub-Contractor shall not proceed with subsequent works of Material Supply or Manufacturing until receiving Code1/Code2 or No Code from PURCHASER. Vendor/Sub-Contractor shall resubmit the document with the same revision within 6 working days after receiving comments.
No code	<input type="checkbox"/> No Code (Applicable Only for "For Information" Documents and "As Built DWGs") Document has been submitted for PURCHASER's Information (FI). Consistency, completeness and correctness of document content is in Vendor/Sub-Contractor's responsibility.

Above checking results by EIED shall in no way relieve Vendor of any liability, obligation and responsibility out of the purchase order and the mutual agreement in writing.

 Energy Industries Engineering & Design co.	Date: May. 11, 2026
	Dept.: MA
	Signature: F.Hamooni

Rev.	DATE	PURPOSE OF ISSUE	PREPARED	CHECKED	APPROVED
02	26-Apr-26	IFR	R.G	F.T	A.M
01	22-Feb-26	IFR	R.G	F.T	A.M
00	20-Jan-26	IFR	R.G	F.T	A.M

IN-01. Native file (Excel) shall be submitted with PDF file for preparing the list of cables that supplied by Customer. This document will be code 3 until we receive Excel file.

 	Gachsaran Polymer Industries Company HDPE Plant Instrument Cable List for Refrigerator Package					
	Document Number	Rev.				
PO No. GPIC-PT-MA-PO-000-3029	VD-GPIC-MA-3029-3029-0052				02	Page: 3 of 8

COMPRESSOR C-6101A/B

No.	Service	Tag No.	Content of signal	SIGNAL Type	IS/NIS	Cable type	Cable size	Gland size	Cable Tag.	From	To	Length Meter+20%	Remarks
1	Compressor A Suction pressure transmitter	PT-61111	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61111	PT-61111	JB-UIA-611	10	
2	Common Discharge pressure transmitter	PT-61131	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61131	PT-61131	JB-UIA-611	10	
3	Oil Supply- Compressor A pressure transmitter	PT-61113	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61113	PT-61113	JB-UIA-611	10	
4	Upstream oil filter pressure transmitter	PT-61133	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61133	PT-61133	JB-UIA-611	10	
5	Coalescer Element Outlet pressure transmitter	PT-61132	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61132	PT-61132	JB-UIA-611	10	
6	Downstream oil filter pressure transmitter	PT-61134	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61134	PT-61134	JB-UIA-611	10	
7	Compressor A Suction temperature transmitter	TT-61111	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TT-61111	TT-61111	JB-UIA-611	10	
8	Oil Separator temperature transmitter	TT-61131	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TT-61131	TT-61131	JB-UIA-611	10	
9	Oil header compressor temperature transmitter	TT-61132	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TT-61132	TT-61132	JB-UIA-611	10	
10	Oil Separator level	LT-61131	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	LT-61131	LT-61131	JB-UIA-611	10	
11	Compressor A slide valve position sensor	ZE-61111	3-wire	Analogue	IS	PVC Blue	01Tx1.5mm ²	M20	ZE-61111	ZE-61111	JB-UIA-611	10	
12	Multi cable for JB-UIA-611 -#1	IC-UIA-611	4 to 20mA	Analogue	IS	FRT-19Px1mm ² SCR/OSCR/SWA/IS/BLUE (300/500)	19x2x1 mm ²	M40	IC-UIA-611	P-6101	JB-UIA-611	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
13	Compressor B Suction pressure transmitter	PT-61121	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61121	PT-61121	JB-UIA-621	10	
14	Oil	PT-61123	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61123	PT-61123	JB-UIA-621	10	
15	Compressor B suction temperature transmitter	TT-61121	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TT-61121	TT-61121	JB-UIA-621	10	
16	Compressor B slide valve position sensor	ZE-61121	3-wire	Analogue	IS	(CU/XLPE/PVC/SWA/PVC) Blue	01Tx1.5mm ²	M20	ZE-61121	ZE-61121	JB-UIA-621	10	
17	Multi cable for JB-UIA-621 -#1	IC-UIA-621	4 to 20mA	Analogue	IS	FRT-07Px1mm ² SCR/OSCR/SWA/IS/BLUE (300/500)	7x2x1 mm ²	M25	IC-UIA-621	P-6101	JB-UIA-621	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
18	ECONOMIZER TUBESIDE TEMPERATURE	TT-61141	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TT-61141	TT-61141	JB-UIA-641	10	
19	ECONOMIZER TUBESIDE PRESSURE	PT-61141	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PT-61141	PT-61141	JB-UIA-641	10	
20	Chiller level transmitter	LT-61151	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	LT-61151	LT-61151	JB-UIA-641	10	
21	Chiller level control	LV-61151	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	LV-61151	LV-61151	JB-UIA-641	10	
22	Hot Gas Bypass control	PV-61151	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	PV-61151	PV-61151	JB-UIA-641	10	
23	ECONOMIZER TEMPERATURE CONTROL VALVE	TV-61141	4 to 20mA / 2-wire	Analogue	IS	Type 1	01Px1.5mm ²	M20	TV-61141	TV-61141	JB-UIA-641	10	
24	Multi cable for JB-UIA-641	IC-UIA-641	4 to 20mA	Analogue	IS	FRT-02Px1.5mm ² SCR/OSCR/SWA/IS/BLUE (300/500)	2x2x1.5 mm ²	By Client	IC-25-61111	P-6101	JB-UIA-641	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
25	COMPRESSOR -A- SLIDE VALVE 100%	ZSH-61111	24Vdc / **W	Digital	IS	Type 1	01Px1.5mm ²	M20	ZSH-61111	ZSH-61111	JB-UIA-611	10	
26	COMPRESSOR -A- SLIDE VALVE 0%	ZSL-61111	24Vdc / **W	Digital	IS	Type 1	01Px1.5mm ²	M20	ZSL-61111	ZSL-61111	JB-UIA-611	10	
27	Multi cable for JB-UIA-611 -#2	ZS-61111	24Vdc / **W	Digital	IS	FRT-02Px1.5mm ² OSCR/SWA/IS/BLUE (300/500)	2x2x1.5 mm ²	By Client	IC-25-61111	P-6101	JB-UIA-611	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
28	COMPRESSOR -B- SLIDE VALVE 100%	ZSH-61121	24Vdc / **W	Digital	IS	Type 1	01Px1.5mm ²	M20	ZSH-61121	ZSH-61121	JB-UIA-621	10	
29	COMPRESSOR -B- SLIDE VALVE 0%	ZSL-61121	24Vdc / **W	Digital	IS	Type 1	01Px1.5mm ²	M20	ZSL-61121	ZSL-61121	JB-UIA-621	10	
30	Multi cable for JB-UIA-621 -#2	ZS-61121	24Vdc / **W	Digital	IS	FRT-02Px1.5mm ² OSCR/SWA/IS/BLUE (300/500)	2x2x1.5 mm ²	By Client	IC-25-61121	P-6101	JB-UIA-621	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer



Gachsaran Polymer Industries Company
HDPE Plant
Instrument Cable List for Refrigerator Package



PO No. GPIC-PT-MA-PO-000-3029	Document Number VD-GPIC-MA-3029-3029-0052	Rev. 02	Page: 4 of 8
-------------------------------	--	------------	--------------

Add: "spare"

COMPRESSOR C-6101A/B

No.	Service	Tag No.	Content of signal	SIGNAL Type	IS/NIS	Cable type	Cable size	Gland size	Cable Tag.	From	To	Length Meter(+20%)	Remarks
31	COMPRESSOR -A- SLIDE VALVE UNLOAD SOV	XY-61111	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61111	XY-61111	JB-UEV-612	10	
32	COMPRESSOR -A- SLIDE VALVE LOAD SOV	XY-61112	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61112	XY-61112	JB-UEV-612	10	
33	Multi cable for JB-UEV-612	IC-UEV-612	24Vdc / **W	Digital	NIS	FRT-04Px2.5mm ² SWA/NIS/GRAY (300/500)	4x2x2.5 mm ²	M32	IC-UEV-612	JB-UEV-612	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
34	COMPRESSOR -B- SLIDE VALVE UNLOAD SOV	XY-61121	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61121	XY-61121	JB-UEV-622	10	
35	COMPRESSOR -B- SLIDE VALVE LOAD SOV	XY-61122	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61122	XY-61122	JB-UEV-622	10	
36	Multi cable for JB-UEV-622	IC-UEV-622	24Vdc / **W	Digital	NIS	FRT-04Px2.5mm ² SWA/NIS/GRAY (300/500)	4x2x2.5 mm ²	M32	IC-UEV-622	JB-UEV-622	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
37	OIL RECOVERY VALVE SOV - COMPRESSOR DISCHARGE	XY-61151	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61151	XY-61151	JB-UEV-652	10	
38	OIL RECOVERY VALVE SOV - CHILLER RECOVERY	XY-61152	24Vdc / **W	Digital	NIS	Type 2	01Px2.5mm ²	M20	XY-61152	XY-61152	JB-UEV-652	10	
39	Multi cable for JB-UEV-652	IC-UEV-652	24Vdc / **W	Digital	NIS	FRT-04Px2.5mm ² SWA/NIS/GRAY (300/500)	4x2x2.5 mm ²	M32	IC-UEV-652	JB-UEV-652	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
40	Oil heater temp. control switch High/High High	EH6101/TSHH-EH6101	24Vdc / **D	Digital	NIS	FRT-01Px1.5mm ² OSCR/SWA/NIS/GRAY (300/500)	1x2x1.5mm ²	M20	TS-EH6101	TS-EH6101	MCC	350	2-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
41	COMPRESSOR -A- MOTOR CURRENT	IT-61111	4 to 20mA / 2-wire	Analogue	NIS	By Client	2Px1.5mm ² /Pr. 1	M20			UCP-6101		2-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
42	COMPRESSOR -B- MOTOR CURRENT	IT-61121	4 to 20mA / 2-wire	Analogue	NIS	By Client	2Px1.5mm ² /Pr. 2	M20	IT-UCP6101	MCC	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
43	COMPRESSOR MOTOR -B- BEARING TEMP NDE/DE	TE-61127	RTD / 3-wire	Pt100	IS	By Client	4Tx1.5mm ² /Tr. 1	M20	RTDBOX-B-UCP	Motor JB-B	UCP-6101		1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
44	COMPRESSOR MOTOR -B- BEARING TEMP NDE/DE	TE-61127/28	RTD / 3 wire	Pt100	IS	FRT-04Tx1mm ² SCR/OSCR/SWA/IS (300/500)	4Tx1 mm ²	M32	UCP-RTDBOX-B	Motor JB-B	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
45	COMPRESSOR MOTOR -A- BEARING TEMP NDE/DE	TE-61117	RTD / 3-wire	Pt100	IS	By Client	4Tx1.5mm ² /Tr. 1	M20	RTDBOX-A-UCP	Motor JB-A	UCP-6101		1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
46	COMPRESSOR MOTOR -A- BEARING TEMP NDE/DE	TE-61117/18	RTD / 3 wire	Pt100	IS	FRT-04Tx1mm ² SCR/OSCR/SWA/IS (300/500)	4Tx1 mm ²	M32	UCP-RTDBOX-A	Motor JB-A	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
47	CHILLER TUBE OUTLET TEMPATURE	TIC-61101	4 to 20mA / 2-wire	Analogue	IS	FRT-01Px1.5mm ² OSCR/IS/BLUE (300/500)	1Px1.5mm ²	M20	TIC-61101	DCS	UCP-6101	50	

shall be deleted.

These rows shall be removed completely from this list in the next rev.

Cable will be supplied by Electrical of Customer.














**Gachsaran Polymer Industries Company
HDPE Plant
Instrument Cable List for Refrigerator Package**







Document Number	Rev.	Page: 5 of 8
VD-GPIC-MA-3	02	Add: "spare"

No.	Service	Tag No.	Content of signal	SIGNAL Type	IS/NIS	Cable type	Cable size	Gland size	Cable Tag.	From	To	Length Meter(+20%)	Remarks
48	Motor Winding TEMPERATURE	TI-61119	4-to-20mA / 2-wire	Analogue	NIS	By Client	2Px1.5mm ² /Pr-1	M20	CM-6101-RTD	MCC	DCS	400-	
49	Motor Winding TEMPERATURE	TI-61129	4-to-20mA / 2-wire	Analogue	NIS	By Client	2Px1.5mm ² /Pr-2	M20	CM-6101-RTD	MCC	DCS	400-	
50	Plant Emergency Stop	ESD-61010	24Vdc / **D	Digital	NIS	FRT-01Px1.5mm ² OSCR/NIS/GRAY (300/500)	1Px1.5mm ²	M20	UCP-61010	ESD	UCP-6101	50	
51	CUMULATIVE ALARM	XA-61101	24Vdc / **D	Digital	NIS	FRT-01Px1.5mm ² OSCR/NIS/GRAY (300/500)	1Px1.5mm ²	M20	UCP-DCS	UCP-6101	DCS		
52	CUMULATIVE TRIP	XA-61102	24Vdc / **D	Digital	NIS	FRT-01Px1.5mm ² OSCR/NIS/GRAY (300/500)	1Px1.5mm ²	M20	UCP-DCS	UCP-6101	DCS		
53	Time Synchronization Signal	TS-6101	24Vdc / **D	Digital	NIS	FRT-01Px1.5mm ² OSCR/NIS/GRAY (300/500)	1Px1.5mm ²	M20	UCP-DCS	DCS	UCP-6101		
54	LCP-A- Switches	UCP-LCP-6101A-1	24Vdc / **D	Digital	NIS	FRT-19Px1mm ² OSCR/SWA/NIS/GRAY (300/500)	19Px1 mm ²	M32	UCP-LCP-6101A-1	LCP-6101A	UCP-6101	350	
55	LCP -A-Lamps	UCP-LCP-6101A-2	24Vdc / **D	Digital	NIS	FRT-07Px2.5mm ² SWA/NIS/GRAY(300/500)	7Px2.5 mm ²	M32	UCP-LCP-6101A-2	LCP-6101A	UCP-6101	350	1-Cable will be supplied By Customer 2-Cable size shall be checked and confirmed by Customer
56	LCP-B- Switches	UCP-LCP-6101B-1	24Vdc / **D	Digital	NIS	FRT-07Px1mm ² SWA/NIS/GRAY(300/500)	7Px1 mm ²	M25	UCP-LCP-6101B-1	LCP-6101B	UCP-6101	350	
57	LCP -B-Lamps	UCP-LCP-6101B-2	24Vdc / **D	Digital	NIS	FRT-04Px2.5mm ² SWA/NIS/GRAY(300/500)	4Px2.5 mm ²	M32	UCP-LCP-6101B-2	LCP-6101B	UCP-6101	350	
58	UCP to MCC (UCP Digital Output Command signals for main motor A, main motor B, oil pump, Elec. Heater :STT,STP, ETC)		24Vdc / **D	Digital	NIS	By Client	12x2x2.5 mm ²	By Client	Hold			350	shall be deleted.
59	MCC to UCP (UCP Digital Input Status signals for main motor A, main motor B, oil pump, Elec. Heater : Running,Fault, ETC)		24Vdc / **D	Digital	NIS	By Client				MCC	UCP-6101	350	Cable will be supplied by Electrical of Customer.
60	Communication with DCS			Modbus TCP/IP		By Client			DCS-UCP-6101-1	UCP	DCS	50	
61	Communication with DCS			Modbus TCP/IP		By Client			DCS-UCP-6101-2	UCP	DCS	50	Redundant
62	UPS Power _110 Vac -#1			Power cable			CU/XLPE/PVC (600/1000) Black	02Cx6mm2	PDP-UCP-6101-1	Instrument PDP	UCP	50	1-Cable will be supplied By Customer
63	UPS Power _110 Vac -#2			Power cable			CU/XLPE/PVC (600/1000) Black	02Cx6mm2	PDP-UCP-6101-2	Instrument PDP	UCP	50	2-Cable size shall be checked and confirmed by Customer
64	Non-UPS Power			Power cable			CU/XLPE/PVC (600/1000) Black	02Cx4mm2	PDP-UCP-6101-3	Instrument PDP	UCP	50	

  Gachhsaran Polymer Industries Company		Gachhsaran Polymer Industries Company HDPE Plant Instrument Cable List for Refrigerator Package			 EIED			
		Document Number		Rev.		 		
PO No. GPIC-PT-MA-PO-000-3029		VD-GPIC-MA-3029-3029-0052			02		Page: 6 of 8	
								Rev.
1	Item	1						
2	DUTY	2 Wire Transmitter,						
3	INSTALLATION LOCATION	OUTDOOR						
4	INSTALLATION METHOD	-						
5	AMBIENT TEMP MIN / MAX	-20 °C / 48 °C						
6	CABLE TECHNICAL DATA							
7	MAKE	Moghan Cable						
8	TYPE	As per EN50288-7						
9	CONDUCTORS	Tinned Stranded Copper - IEC 60228 class 2						
10	INSULATION	XLPE						
11	CORE / PAIR / TRIAD	Twisted Pair						
12	IDENTIFICATION	Black - white						
13	SCREENING	Collective Aluminium/Polyester tape + tinned copper drain wire						
14	BEDDING	LSHF						
15	ARMOUR	Galvanised Steel Wire Armour (SWA)						
16	OUTER JACKET	LSHF						
17	OUTER SHEATH COLOUR	Blue						
18	CROSS SECTION	1.5 mm ²						
19	NUMBER OF CORES / PARE / TRIADS	1 Pair						
20	MAX. OPERATING VOLTAGE	300 / 500 Volt						
21	MIN. OPERATING TEMPERATURE	-20 °C						
22	MAX. OPERATING TEMPERATURE	+60 °C						
23	CONDUCTOR MAXIMUM TEMPERATURE	+90 °C						
24								
25	INNER SHEATH DIAMETER	7.7 mm						
26	OUTER SHEATH DIAMETER	12.5 mm						
27								
28	FLAME RETARDANT	IEC60332-1-2 / IEC 60332-3-24 (cat.C)						
29								
30								
31								
32								
33								
34								
35								

 		Gachsaran Polymer Industries Company HDPE Plant Instrument Cable List for Refrigerator Package			
		Document Number	Rev.	 	
PO No. GPIC-PT-MA-PO-000-3029		VD-GPIC-MA-3029-3029-0052	02	Page: 7 of 8	
					Rev.
1	Item	2			
2	DUTY	SOLENOID VALVE			
3	INSTALLATION LOCATION	OUTDOOR			
4	INSTALLATION METHOD	-			
5	AMBIENT TEMP MIN / MAX	-20 °C / 48 °C			
6	CABLE TECHNICAL DATA				
7	MAKE	Moghan Cable			
8	TYPE	As per EN50288-7			
9	CONDUCTORS	Tinned Stranded Copper - IEC 60228 class 2			
10	INSULATION	XLPE			
11	CORE / PAIR / TRIAD	Pair			
12	IDENTIFICATION	Black - white			
13	SCREENING	NA			
14	BEDDING	LSHF			
15	ARMOUR	Galvanised Steel Wire Armour (SWA)			
16	OUTER JACKET	LSHF			
17	OUTER SHEATH COLOUR	Gray			
18	CROSS SECTION	2.5 mm ²			
19	NUMBER OF CORES / PARE / TRIADS	1 Pair			
20	MAX. OPERATING VOLTAGE	300 / 500 Volt			
21	MIN. OPERATING TEMPERATURE	-20 °C			
22	MAX. OPERATING TEMPERATURE	+60 °C			
23	CONDUCTOR MAXIMUM TEMPERATURE	+90 °C			
24					
25	INNER SHEATH DIAMETER	8.9 mm			
26	OUTER SHEATH DIAMETER	13.7 mm			
27					
28	FLAME RETARDANT	IEC60332-1-2 / IEC 60332-3-24 (cat.C)			
29					
30					
31					
32					
33					
34					
35					

 		Gachsaran Polymer Industries Company HDPE Plant Instrument Cable List for Refrigerator Package		 		
Document Number		Rev.		Page: 8 of 8		
PO No. GPIC-PT-MA-PO-000-3029		VD-GPIC-MA-3029-3029-0052		02		
Item					Rev.	
1	Item	3				
2	DUTY	Switches				
3	INSTALLATION LOCATION	OUTDOOR				
4	INSTALLATION METHOD	-				
5	AMBIENT TEMP MIN / MAX	-20 °C / 48 °C				
		<div style="border: 1px solid red; padding: 2px; display: inline-block;">shall be specified.</div>				
6	CABLE TECHNICAL DATA					
7	MAKE	LAYER				
8	TYPE	As per EN50288-7				
9	CONDUCTORS	Stranded Copper - IEC 60228 class 2				
10	INSULATION	XLPE				
11	CORE / PAIR / TRIAD	Twisted Pair				
12	IDENTIFICATION	Black - white				
13	SCREENING	Collective Aluminium/Maylar tape + tinned copper drain wire				
14	BEDDING	PVC				
15	ARMOUR	Galvanised Steel Wire Armour (SWA)				
16	OUTER JACKET	PVC				
17	OUTER SHEATH COLOUR	Blue				
18	CROSS SECTION	1.5 mm ²				
19	NUMBER OF CORES / PARE / TRIADS	2 Pair				
20	MAX. OPERATING VOLTAGE	300 / 500 Volt				
21	MIN. OPERATING TEMPERATURE	-20 °C				
22	MAX. OPERATING TEMPERATURE	+60 °C				
23	CONDUCTOR MAXIMUM TEMPERATURE	+90 °C				
24						
25	INNER SHEATH DIAMETER	Later				
26	OUTER SHEATH DIAMETER	Later				
27						
28	FLAME RETARDANT	IEC60332-1-2 / IEC 60332-3-24 (cat.C)				
29						
30						
31						
32						
33						
34						
35						